





Product designation Product type designation			Power contactor BGP09
Contact characteristics			20.00
Number of poles		Nr.	3
Rated insulation voltage Ui IEC/EN		V	500
Rated impulse withstand voltage Uimp		kV	6
Operational frequency			·
	min	Hz	25
	max	Hz	400
IEC Conventional free air thermal current Ith		Α	20
Operational current le			
	AC-1 (≤40°C)	Α	20
	AC-1 (≤55°C)	Α	18
	AC-1 (≤70°C)	Α	15
	AC-3 (≤440V ≤55°C)	Α	9
	AC-4 (400V)	Α	4
Rated operational power AC-3 (T≤55°C)			
	230V	kW	2.2
	400V	kW	4
	415V	kW	4.3
	440V	kW	4.5
	500V	kW	5
Rated operational power AC-1 (T≤40°C)			
	230V	kW	8
	400V	kW	14
	500V	kW	16
Short-time allowable current for 10s (IEC/EN60947-1)		Α	96
Protection fuse			
	gG (IEC)	Α	20
	aM (IEC)	Α	10
Making capacity (RMS value)		Α	92
Breaking capacity at voltage			
	440V	Α	72
	500V	Α	72
Resistance per pole (average value)		mΩ	10
Power dissipation per pole (average value)			
	Ith	W	4
	AC-3	W	0.81
Tightening torque for terminals			
	min	Nm	0.8
	max	Nm	1
	min	Ibin	9
	max	Ibin	9
Tightening torque for coil terminal	min	Nm	0.8





	max	Nm	1
	min		9
	max		9
	simultaneously connectable	Nr.	2
Conductor section			
	AWG/Kcmil		
	max		12
	Flexible w/o lug conductor section		
	min		0.8
	max	mm²	2.5
	Flexible c/w lug conductor section		
	min	mm²	1.5
	max	mm²	2.5
	Flexible with insulated spade lug conductor section		
	min	mm²	1.5
	max	mm²	2.5
Power terminal prote	ction according to IEC/EN 60529		IP00
Mechanical features			
Operating position			
	norma		Vertical plan
	allowable		±30°
			Screw / DIN rail
Fixing			35mm
Weight		g	195
Auxiliary contact char	acteristics		
Thermal current Ith		Α	10
IEC/EN 60947-5-1 de	esignation		A600 - Q600
Operating current AC			
- p - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1	230V	Α	3
	400V		1.9
	500V		1.4
Operating current DC		,,	
operating earrent be	110V	Α	2.9
Operating current DC			2.5
Operating current DC	24V	Α	2.9
	48V		1.4
	60V		1.1
	125V		0.3
	220V		0.3
	600V		0.6
Operations	600 V	A	0.0
Mechanical life		cycloc	20000000
Electrical life		cycles	500000
		cycles	500000
Safety related data	10d apparding to FN/ISO 42490 4		
renormance level B	10d according to EN/ISO 13489-1		E00000
	rated load	•	500000
EN 40	mechanical load	cycles	20000000
EMC compatibility			yes
AC coil operating			
Rated AC voltage at		V	400
AC operating voltage			

of 50/60Hz coil powered at 50Hz pick-up






			min	%Us	75
			max	%Us	115
		drop-out	man		
		arop out	min	%Us	20
			max	%Us	55
	of E0/60U- coll person	ared at 60U-	IIIaX	/005	JJ
	of 50/60Hz coil power				
		pick-up		0/11-	0.0
			min	%Us	80
			max	%Us	115
		drop-out			
			min	%Us	20
			max	%Us	55
AC average coil cons	umption at 20°C				·
	of 50/60Hz coil power	ered at 50Hz			
	'		in-rush	VA	30
			holding	VA	4
	of 50/60Hz coil power	ered at 60Hz			•
	31 30/301 12 3011 powe	0100 Ut 00112	in-rush	VA	25
				VA VA	3
	of COLL- apil	d at COLI-	holding	VA	J
	of 60Hz coil powered	u at 6UHZ	,) /A	0.0
			in-rush	VA	30
			holding	VA	4
Dissipation at holding				W	0.95
Max cycles frequency					
Mechanical operation				cycles/h	3600
				cycles/h	3600
Mechanical operation	control			cycles/h	3600
Mechanical operation Operating times	control in AC			cycles/h	3600
Mechanical operation Operating times		Closina NO		cycles/h	3600
Mechanical operation Operating times		Closing NO	min		
Mechanical operation Operating times		Closing NO	min max	ms	12
Mechanical operation Operating times		-	min max		
Mechanical operation Operating times		Closing NO Opening NO	max	ms ms	12 21
Mechanical operation Operating times		-	max min	ms ms	12 21 9
Mechanical operation Operating times		Opening NO	max	ms ms	12 21
Mechanical operation Operating times		-	max min max	ms ms ms	12 21 9 18
Mechanical operation Operating times		Opening NO	max min max min	ms ms ms ms	12 21 9 18
Mechanical operation Operating times		Opening NO Closing NC	max min max	ms ms ms	12 21 9 18
Mechanical operation Operating times		Opening NO	max min max min	ms ms ms ms	12 21 9 18
Mechanical operation Operating times		Opening NO Closing NC	max min max min	ms ms ms ms	12 21 9 18
Mechanical operation Operating times		Opening NO Closing NC	max min max min max	ms ms ms ms	12 21 9 18 17 26
Mechanical operation Operating times	in AC	Opening NO Closing NC	max min max min max min	ms ms ms ms ms	12 21 9 18 17 26
Mechanical operation Operating times		Opening NO Closing NC Opening NC	max min max min max min	ms ms ms ms ms	12 21 9 18 17 26
Mechanical operation Operating times	in AC	Opening NO Closing NC	max min max min max min max	ms ms ms ms ms	12 21 9 18 17 26 7
Mechanical operation Operating times	in AC	Opening NO Closing NC Opening NC	max min max min max min max min max	ms ms ms ms ms ms	12 21 9 18 17 26 7 17
Mechanical operation Operating times	in AC	Opening NO Closing NC Opening NC Closing NO	max min max min max min max	ms ms ms ms ms	12 21 9 18 17 26 7
Mechanical operation Operating times	in AC	Opening NO Closing NC Opening NC	max min max min max min max min max	ms ms ms ms ms ms	12 21 9 18 17 26 7 17
Mechanical operation Operating times	in AC	Opening NO Closing NC Opening NC Closing NO	max min max min max min max min max min max min	ms ms ms ms ms ms ms	12 21 9 18 17 26 7 17
Mechanical operation Operating times	in AC	Opening NO Closing NC Opening NC Closing NO Opening NO	max min max min max min max min max	ms ms ms ms ms ms	12 21 9 18 17 26 7 17
Mechanical operation Operating times	in AC	Opening NO Closing NC Opening NC Closing NO	max min max min max min max min max min max	ms ms ms ms ms ms	12 21 9 18 17 26 7 17
Mechanical operation Operating times	in AC	Opening NO Closing NC Opening NC Closing NO Opening NO	max min max min max min max min max min max min max min max min max	ms	12 21 9 18 17 26 7 17
Mechanical operation Operating times	in AC	Opening NO Closing NC Opening NO Closing NO Opening NO Closing NO Closing NC	max min max min max min max min max min max	ms ms ms ms ms ms	12 21 9 18 17 26 7 17
Mechanical operation Operating times	in AC	Opening NO Closing NC Opening NC Closing NO Opening NO	max min max min max min max min max min max min max min max min max	ms	12 21 9 18 17 26 7 17
Mechanical operation Operating times	in AC	Opening NO Closing NC Opening NO Closing NO Opening NO Closing NO Closing NC	max min max min max min max min max min max min max min max min max	ms	12 21 9 18 17 26 7 17
Mechanical operation Operating times	in AC	Opening NO Closing NC Opening NO Closing NO Opening NO Closing NO Closing NC	max min max min max min max min max min max min max min max	ms	12 21 9 18 17 26 7 17 18 25 2 3 3 5



Full-load current (FL	_A) for three-phase AC motor			
		at 480V	Α	7.6
		at 600V	Α	6.1
Yielded mechanical	performance			
	for single-phase AC motor			
	•	110/120V	HP	0.5
		230V	HP	1.5
	for three-phase AC motor			
	·	200/208V	HP	2
		220/230V	HP	3
		460/480V	HP	5
		575/600V	HP	5
General USE				
	Contactor			
		AC current	Α	20
Contact rating of aux	xiliary contacts according to UL			A600 - Q600
Ambient conditions	·			
Temperature				
·	Operating temperature			
		min	°C	-50
		max	°C	+70
	Storage temperature			
	.	min	°C	-60
		max	°C	+80
Max altitude			m	3000
Resistance & Protect	ction			
Pollution degree				3
5 2 2 3 3 2				




• Recommended PCB drillings 1.7-2mm.

Wiring diagrams

Dimensions

ENERGY AND AUTOMATION

THREE-POLE CONTACTOR, IEC OPERATING CURRENT IE (AC3) = 9A, AC COIL 50/60HZ, 400VAC, 1NO AUXILIARY CONTACT, REAR PCB SOLDER PIN



Certifications and compliance

Compliance

CSA C22.2 n° 60947-1

CSA C22.2 n° 60947-4-1

IEC/EN 60947-1

IEC/EN 60947-4-1

UL 60947-1

UL 60947-4-1

Certificates

cURus

EAC

ETIM classification

ETIM 8.0

EC000066 -Power contactor, AC switching